



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



Phone: 0381-232-6451

Email: dg.fire-tr@gov.in

website:www.fireservice.tripura.gov.in

No: FSRTFES/2022/00263

Dated: 10/01/2023

To,
Arindam Sarkar
Kailashahar, Unakoti
Srirampur B.O - 799277

Sub: **Fire Safety Recommendation** For Application Reference No **FSRTFES/2022/00263** .

With reference to your Application Reference No FSRTFES/2022/00263 Dated 09/01/2023 Fire Safety Recommendation on fire prevention and fire safety measures of the following building/premises is hereby issued in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules.

Name of the Applicant:	Arindam Sarkar			
Name of Owner with Plot details:	S. No.	Owner Name and Address		
	1.	ত্রিপুরা সরকারের পক্ষে দংশিক্ষাবিভাগ কর্তিক রক্ষিত		
	S. No.	Plot No	Total Area	Classification
	1.	645	0.13	টিলা
	2.	646	1.17	টিলা
	3.	648	0.33	----
	4.	649	0.16	লুঙ্গা
Name of the Property/ Organization/ Commercial establishment	Srirampur S.M H.S School			
Address of the Building/ Premises:	Habitation, Srirampur Gram Panchayat, Chandipur Block, Post Office Srirampur B.O - 799277, Unakoti District, Tripura.			

A Fire Safety Certificate (FSC) will be issued, subject to verification of compliance of fire prevention and fire safety measures on which the fire safety recommendations enumerated in the attached letter and further submission of application through online system.

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala


***** WE SERVE TO SAVE *****

This certificate shall not be used by the Insurance service provider

Fire Safety Advisory and Suggestion:

- 3 meter
- 3 meter
- 10 meter
- 03 (Three) nos staircase constructed in the school building of upper floor.
- 2 meter upper floor staircase constructed.
- 1 no staircase constructed at the school building
- 02 meter corridor(varrandha) constructed of the school building
- 1.5 meter constructed of the school building.
- 1 no co2 fire extinguisher having capacity of 4.5 kg to be installed near electric panel board, 1 no co2 fire extinguisher having capacity 02 kg to be install in the H.M room, 1 no co2 fire extinguisher capacity of 2 kg install in the each sience lab room.
- 1 no ABC fire extinguisher capacity of 4 kg installed in the teachers common room, ABC fire extinguisher capacity of 6 kg intalled at school varandha 01(one) each interval 15 meters ground floor& first floor.
- 1 no hose reel point 30 meter long to be install every floor connects with down comer system.
- 30 meter long should be install
- 19 mm
- Front side of the building at varrandha
- 100 mm down comer system to be provided at school building
- Double door hose box with accessories that is delivery hose, short branch to be provided near the hose reel point.
- Double door hose box with accessories that is delivery hose, short branch to be provided near the hose reel point each floor.
- Terrace level minimum discharge of 3.5 kg/cm2 to be install in terrace level connects with tyerrace level tank
- 50 meter
- 03 phase to be provided
- Terrace level Auto starting pump, pressure gauge & air release valve to be installe
- 5000 litre to be constructed exclusively fire fighting purpose.
- trained person fire fighters to be engage to operate fire fighting equipments in case of any emergency
- On the above may be issue fire safety advisory in favour of applicant to provide our recommendetion final inspection would be done after installation fire fighting equipments for getting final noc from our end
- forwarded to the DFO unakoti KLS doing the needful please

Signature Not Verified

Digitally signed by  Signer Name
Date: 2023.01.10 18:04:02 IST



Srirampur SM HS School

(A CBSE Affiliated Vidyajyoti School under Govt. of Tripura)

CBSE Affiliation No:-2020244. CBSE School Code:-37663

Kailashahar, Unakoti, Tripura.

e-mail ID- hm16080400406@gmail.com

No.F.2(Gen-32) /Vidyajyoti/ SSMHSS/KLS/2015/ 59

Dated, Kailashahar, the 20th May, 2026.

UNDERTAKING REGARDING FIRE SAFETY CERTIFICATE

To Whom It May Concern

I, Arindam Sarkar, Vice-Principal, Srirampur SM HS School, Kailashahar, Tripura, do hereby declare that the process for installation of fire safety equipment has been initiated in the school, in compliance of the Fire Safety Advisory issued by the concerned authority and the same will be completed very shortly.

(Arindam Sarkar)
Vice- Principal
(H.O & DDO)

Srirampur SM HS School,
Kailashahar, Unakoti, Tripura